

**Bugaldie Water Supply - Microbiological Test Results
(from the NSW Drinking Water Database)**

Sample Collection Date	Tested Parameter	Units	Test Result	ADWG Guideline Values Health	ADWG Guideline Values Aesthetic	Laboratory Comments
9/10/2024	pH		7.3500		6.5 - 8.5	
9/10/2024	Free Chlorine	mg/L	1.6300	0.2 - 5		
9/10/2024	E. coli	mpn/100 mL	< 1	0		
9/10/2024	Temperature	C	19.4000		30	
9/10/2024	Turbidity	NTU	0.8600		5	
9/10/2024	Total Coliforms	mpn/100 mL	< 1	0		
9/10/2024	Total Chlorine	mg/L	1.7300	5		
3/09/2024	pH		7.0700		6.5 - 8.5	,Field result entered as provided
3/09/2024	Free Chlorine	mg/L	1.8100	0.2 - 5		,Field result entered as provided
3/09/2024	E. coli	mpn/100 mL	< 1	0		,Field result entered as provided
3/09/2024	Temperature	C	16.5000		30	,Field result entered as provided
3/09/2024	Turbidity	NTU	0.3600		5	,Field result entered as provided
3/09/2024	Total Coliforms	mpn/100 mL	< 1	0		,Field result entered as provided
3/09/2024	Total Chlorine	mg/L	1.7500	5		,Field result entered as provided
6/08/2024	pH		7.2100		6.5 - 8.5	
6/08/2024	Free Chlorine	mg/L	1.6400	0.2 - 5		
6/08/2024	E. coli	mpn/100 mL	< 1	0		
6/08/2024	Temperature	C	12.2000		30	
6/08/2024	Turbidity	NTU	0.6800		5	
6/08/2024	Total Coliforms	mpn/100 mL	< 1	0		
6/08/2024	Total Chlorine	mg/L	1.8100	5		
2/07/2024	pH		7.2700		6.5 - 8.5	,Late but tested
2/07/2024	Free Chlorine	mg/L	1.6600	0.2 - 5		,Late but tested
2/07/2024	E. coli	mpn/100 mL	< 1	0		,Late but tested
2/07/2024	Temperature	C	13.0000		30	,Late but tested
2/07/2024	Turbidity	NTU	0.3200		5	,Late but tested
2/07/2024	Total Coliforms	mpn/100 mL	< 1	0		,Late but tested
2/07/2024	Total Chlorine	mg/L	1.8100	5		,Late but tested
12/06/2024	pH		7.2400		6.5 - 8.5	
12/06/2024	Free Chlorine	mg/L	2.0800	0.2 - 5		
12/06/2024	E. coli	mpn/100 mL	< 1	0		
12/06/2024	Temperature	C	13.5000		30	
12/06/2024	Turbidity	NTU	0.3400		5	
12/06/2024	Total Coliforms	mpn/100 mL	< 1	0		
12/06/2024	Total Chlorine	mg/L	2.1500	5		
1/05/2024	pH		7.5500		6.5 - 8.5	,Field result entered as provided
1/05/2024	Free Chlorine	mg/L	1.2900	0.2 - 5		,Field result entered as provided
1/05/2024	E. coli	mpn/100 mL	< 1	0		,Field result entered as provided
1/05/2024	Temperature	C	18.7000		30	,Field result entered as provided
1/05/2024	Turbidity	NTU	2.1700		5	,Field result entered as provided
1/05/2024	Total Coliforms	mpn/100 mL	< 1	0		,Field result entered as provided
1/05/2024	Total Chlorine	mg/L	1.2500	5		,Field result entered as provided