

**Dunedoo Water Supply - Chemistry Test Results**  
(from the NSW Drinking Water Database)

DateCollected	Characteristic	Units	Test Result	ADWG Health Guideline Value	ADWG Aesthetic Guideline Value
4/03/2024	Aluminium	mg/L	0.01		0.2
4/03/2024	Antimony	mg/L	< 0.0001	0.003	
4/03/2024	Arsenic	mg/L	0.001	0.01	
4/03/2024	Barium	mg/L	0.0885	2	
4/03/2024	Boron	mg/L	0.0608	4	
4/03/2024	Cadmium	mg/L	< 0.0001	0.002	
4/03/2024	Calcium	mg/L	70		10000
4/03/2024	Chloride	mg/L	211		250
4/03/2024	Chromium	mg/L	0.002	0.05	
4/03/2024	Copper	mg/L	0.08	2	1
4/03/2024	Fluoride	mg/L	0.61	1.5	
4/03/2024	Iodine	mg/L	0.06		0.15
4/03/2024	Iron	mg/L	0.07		0.3
4/03/2024	Lead	mg/L	0.0005	0.01	
4/03/2024	Magnesium	mg/L	63.41		10000
4/03/2024	Manganese	mg/L	0.0008	0.5	0.1
4/03/2024	Mercury	mg/L	< 0.0008	0.001	
4/03/2024	Molybdenum	mg/L	0.002	0.05	
4/03/2024	Nickel	mg/L	0.0009	0.02	
4/03/2024	Nitrate	mg/L	3	50	
4/03/2024	Nitrite	mg/L	< 0.1	3	
4/03/2024	pH		7.9		6.5 - 8.5
4/03/2024	Selenium	mg/L	< 0.007	0.01	
4/03/2024	Silver	mg/L	< 0.0002	0.1	
4/03/2024	Sodium	mg/L	110		180
4/03/2024	Sulfate	mg/L	27		250
4/03/2024	Total Dissolved Solids (TDS)	mg/L	598		10000
4/03/2024	Total Hardness as CaCO3	mg/L	435.9		200
4/03/2024	True Colour	Hazen Units (HU)	1		15
4/03/2024	Turbidity	NTU	0.1		5
4/03/2024	Uranium	mg/L	0.0011	0.02	
4/03/2024	Zinc	mg/L	0.12		3