

Coonabarabran Water Supply - Chemistry Sample Test Results
(from the NSW Drinking Water Database)

Date Collected	Tested Parameter	Units	Test Results	Aesthetic Guidleine	Health Guideline Value
24-03-2021	Aluminium	mg/L	< 0.01	0.2	
24-03-2021	Antimony	mg/L	< 0.0001		0.003
24-03-2021	Arsenic	mg/L	0.0020		0.01
24-03-2021	Barium	mg/L	0.0843		2
24-03-2021	Boron	mg/L	0.0730		4
24-03-2021	Cadmium	mg/L	< 0.0001		0.002
24-03-2021	Calcium	mg/L	62.2000		10000
24-03-2021	Chloride	mg/L	201.0000	250	
24-03-2021	Chromium	mg/L	0.0020		0.05
24-03-2021	Copper	mg/L	0.0150	2	
24-03-2021	Fluoride	mg/L	0.6000		1.5
24-03-2021	Iodine	mg/L	0.0700		0.5
24-03-2021	Iron	mg/L	0.0200	0.3	
24-03-2021	Lead	mg/L	0.0014		0.01
24-03-2021	Magnesium	mg/L	53.0300		10000
24-03-2021	Manganese	mg/L	0.0017	0.5	
24-03-2021	Mercury	mg/L	< 0.0008		0.001
24-03-2021	Molybdenum	mg/L	0.0016		0.05
24-03-2021	Nickel	mg/L	0.0004		0.02
24-03-2021	Nitrate	mg/L	2.0000		50
24-03-2021	Nitrite	mg/L	< 0.1		3
24-03-2021	pH		7.6000	6.5 - 8.5	
24-03-2021	Selenium	mg/L	0.0070		0.01
24-03-2021	Silver	mg/L	< 0.0002		0.1
24-03-2021	Sodium	mg/L	106.0000	180	
24-03-2021	Sulfate	mg/L	26.0000	500	
24-03-2021	Total Dissolved Solids (TDS)	mg/L	648.0000	600	
24-03-2021	Total Hardness as CaCO3	mg/L	373.7000	200	
24-03-2021	True Colour	Hazen Units (HU)	< 1	15	
24-03-2021	Turbidity	NTU	0.9000	5	
24-03-2021	Uranium	mg/L	0.0011		0.017
24-03-2021	Zinc	mg/L	0.1800	3	
10-03-2021	Aluminium	mg/L	0.0100	0.2	
10-03-2021	Antimony	mg/L	< 0.0001		0.003
10-03-2021	Arsenic	mg/L	0.0030		0.01
10-03-2021	Barium	mg/L	0.0867		2
10-03-2021	Boron	mg/L	0.0687		4
10-03-2021	Cadmium	mg/L	< 0.0001		0.002
10-03-2021	Calcium	mg/L	70.2000		10000
10-03-2021	Chloride	mg/L	196.0000	250	
10-03-2021	Chromium	mg/L	0.0010		0.05
10-03-2021	Copper	mg/L	0.0230	2	
10-03-2021	Fluoride	mg/L	0.6000		1.5

10-03-2021	Iodine	mg/L	0.0600		0.5
10-03-2021	Iron	mg/L	0.0500	0.3	
10-03-2021	Lead	mg/L	0.0012		0.01
10-03-2021	Magnesium	mg/L	60.8100		10000
10-03-2021	Manganese	mg/L	0.0031	0.5	
10-03-2021	Mercury	mg/L	< 0.0008		0.001
10-03-2021	Molybdenum	mg/L	0.0014		0.05
10-03-2021	Nickel	mg/L	0.0004		0.02
10-03-2021	Nitrate	mg/L	2.0000		50
10-03-2021	Nitrite	mg/L	< 0.1		3
10-03-2021	pH		7.6000	6.5 - 8.5	
10-03-2021	Selenium	mg/L	0.0120		0.01
10-03-2021	Silver	mg/L	< 0.0002		0.1
10-03-2021	Sodium	mg/L	120.0000	180	
10-03-2021	Sulfate	mg/L	25.0000	500	
10-03-2021	Total Dissolved Solids (TDS)	mg/L	655.0000	600	
10-03-2021	Total Hardness as CaCO3	mg/L	425.7000	200	
10-03-2021	True Colour	Hazen Units (HU)	< 1	15	
10-03-2021	Turbidity	NTU	1.7000	5	
10-03-2021	Uranium	mg/L	0.0010		0.017
10-03-2021	Zinc	mg/L	0.1900	3.0000	