

Dunedoo Water Supply - Microbiological Test Results (From the NSW Drinking Water Database)

Sample Collection						
Date	Tested Parameter	Units	Test Results	ADWG Guideline Values Health	ADWG Guideline Values Aesthetic	Laboratory Comments
25/02/2025	E. coli	mpn/100 mL	< 1	0		
25/02/2025	Free Chlorine	mg/L	1.38	0.2 - 5		
25/02/2025	pH		8.12		6.5 - 8.5	
25/02/2025	Temperature	C	31.4		30	
25/02/2025	Total Chlorine	mg/L	1.3	5		
25/02/2025	Total Coliforms	mpn/100 mL	< 1	0		
25/02/2025	Turbidity	NTU	0.01		5	
17/02/2025	E. coli	mpn/100 mL	< 1	0		
17/02/2025	Free Chlorine	mg/L	1.28	0.2 - 5		
17/02/2025	pH		8.12		6.5 - 8.5	
17/02/2025	Temperature	C	28.3		30	
17/02/2025	Total Chlorine	mg/L	1.07	5		
17/02/2025	Total Coliforms	mpn/100 mL	< 1	0		
17/02/2025	Turbidity	NTU	0.15		5	
10/02/2025	E. coli	mpn/100 mL	< 1	0		
10/02/2025	Free Chlorine	mg/L	1.27	0.2 - 5		
10/02/2025	pH		8.07		6.5 - 8.5	
10/02/2025	Temperature	C	30		30	
10/02/2025	Total Chlorine	mg/L	1.32	5		
10/02/2025	Total Coliforms	mpn/100 mL	< 1	0		
10/02/2025	Turbidity	NTU	0		5	
3/02/2025	E. coli	mpn/100 mL	< 1	0		
3/02/2025	Free Chlorine	mg/L	1.45	0.2 - 5		
3/02/2025	pH		8.09		6.5 - 8.5	
3/02/2025	Temperature	C	30		30	
3/02/2025	Total Chlorine	mg/L	1.42	5		
3/02/2025	Total Coliforms	mpn/100 mL	< 1	0		
3/02/2025	Turbidity	NTU	0		5	
28/01/2025	E. coli	mpn/100 mL	< 1	0		
28/01/2025	Free Chlorine	mg/L	1.36	0.2 - 5		
28/01/2025	pH		8.12		6.5 - 8.5	
28/01/2025	Temperature	C	30.9		30	
28/01/2025	Total Chlorine	mg/L	1.27	5		
28/01/2025	Total Coliforms	mpn/100 mL	< 1	0		
28/01/2025	Turbidity	NTU	0		5	
20/01/2025	E. coli	mpn/100 mL	< 1	0		
20/01/2025	Free Chlorine	mg/L	1.48	0.2 - 5		
20/01/2025	pH		8.1		6.5 - 8.5	
20/01/2025	Temperature	C	29.6		30	
20/01/2025	Total Chlorine	mg/L	1.41	5		
20/01/2025	Total Coliforms	mpn/100 mL	< 1	0		
20/01/2025	Turbidity	NTU	0.01		5	
14/01/2025	E. coli	mpn/100 mL	< 1	0		
14/01/2025	Free Chlorine	mg/L	1.24	0.2 - 5		
14/01/2025	pH		8.14		6.5 - 8.5	
14/01/2025	Temperature	C	30		30	
14/01/2025	Total Chlorine	mg/L	1.19	5		
14/01/2025	Total Coliforms	mpn/100 mL	< 1	0		
14/01/2025	Turbidity	NTU	0.01		5	
6/01/2025	E. coli	mpn/100 mL	< 1	0		
6/01/2025	Free Chlorine	mg/L	1.36	0.2 - 5		
6/01/2025	pH		8.13		6.5 - 8.5	
6/01/2025	Temperature	C	29.1		30	

6/01/2025	Total Chlorine	mg/L	1.39	5		
6/01/2025	Total Coliforms	mpn/100 mL	< 1	0		
6/01/2025	Turbidity	NTU	0		5	
16/12/2024	E. coli	mpn/100 mL	< 1	0		
16/12/2024	Free Chlorine	mg/L	1.26	0.2 - 5		
16/12/2024	pH		8.14		6.5 - 8.5	
16/12/2024	Temperature	C	29.6		30	
16/12/2024	Total Chlorine	mg/L	1.27	5		
16/12/2024	Total Coliforms	mpn/100 mL	< 1	0		
16/12/2024	Turbidity	NTU	0.07		5	
9/12/2024	E. coli	mpn/100 mL	< 1	0		
9/12/2024	Free Chlorine	mg/L	1.39	0.2 - 5		
9/12/2024	pH		8.13		6.5 - 8.5	
9/12/2024	Temperature	C	27.3		30	
9/12/2024	Total Chlorine	mg/L	1.39	5		
9/12/2024	Total Coliforms	mpn/100 mL	< 1	0		
9/12/2024	Turbidity	NTU	0.01		5	
2/12/2024	E. coli	mpn/100 mL	< 1	0		
2/12/2024	Free Chlorine	mg/L	1.73	0.2 - 5		
2/12/2024	pH		8.08		6.5 - 8.5	
2/12/2024	Temperature	C	27.2		30	
2/12/2024	Total Chlorine	mg/L	1.64	5		
2/12/2024	Total Coliforms	mpn/100 mL	< 1	0		
2/12/2024	Turbidity	NTU	0		5	
25/11/2024	E. coli	mpn/100 mL	< 1	0		
25/11/2024	Free Chlorine	mg/L	1.24	0.2 - 5		
25/11/2024	pH		8.09		6.5 - 8.5	
25/11/2024	Temperature	C	28.9		30	
25/11/2024	Total Chlorine	mg/L	1.28	5		
25/11/2024	Total Coliforms	mpn/100 mL	< 1	0		
25/11/2024	Turbidity	NTU	0.42		5	
18/11/2024	E. coli	mpn/100 mL	< 1	0		
18/11/2024	Free Chlorine	mg/L	1.78	0.2 - 5		
18/11/2024	pH		8.05		6.5 - 8.5	
18/11/2024	Temperature	C	27.4		30	
18/11/2024	Total Chlorine	mg/L	1.72	5		
18/11/2024	Total Coliforms	mpn/100 mL	< 1	0		
18/11/2024	Turbidity	NTU	0.02		5	
12/11/2024	E. coli	mpn/100 mL	< 1	0		
12/11/2024	Free Chlorine	mg/L	0.38	0.2 - 5		
12/11/2024	pH		8.07		6.5 - 8.5	
12/11/2024	Temperature	C	24.4		30	
12/11/2024	Total Chlorine	mg/L	0.37	5		
12/11/2024	Total Coliforms	mpn/100 mL	< 1	0		
12/11/2024	Turbidity	NTU	0.86		5	
4/11/2024	E. coli	mpn/100 mL	< 1	0		
4/11/2024	Free Chlorine	mg/L	0.77	0.2 - 5		
4/11/2024	pH		8.08		6.5 - 8.5	
4/11/2024	Temperature	C	26.3		30	
4/11/2024	Total Chlorine	mg/L	0.78	5		
4/11/2024	Total Coliforms	mpn/100 mL	< 1	0		
4/11/2024	Turbidity	NTU	0		5	
28/10/2024	E. coli	mpn/100 mL	< 1	0		
28/10/2024	Free Chlorine	mg/L	1.26	0.2 - 5		
28/10/2024	pH		8.09		6.5 - 8.5	
28/10/2024	Temperature	C	26.3		30	
28/10/2024	Total Chlorine	mg/L	1.32	5		
28/10/2024	Total Coliforms	mpn/100 mL	< 1	0		
28/10/2024	Turbidity	NTU	0		5	

21/10/2024	E. coli	mpn/100 mL	< 1	0		
21/10/2024	Free Chlorine	mg/L	1.31	0.2 - 5		
21/10/2024	pH		8.13		6.5 - 8.5	
21/10/2024	Temperature	C	23.1		30	
21/10/2024	Total Chlorine	mg/L	1.32	5		
21/10/2024	Total Coliforms	mpn/100 mL	< 1	0		
21/10/2024	Turbidity	NTU	0		5	
14/10/2024	E. coli	mpn/100 mL	< 1	0		
14/10/2024	Free Chlorine	mg/L	1.38	0.2 - 5		
14/10/2024	pH		8.04		6.5 - 8.5	
14/10/2024	Temperature	C	24.1		30	
14/10/2024	Total Chlorine	mg/L	1.36	5		
14/10/2024	Total Coliforms	mpn/100 mL	< 1	0		
14/10/2024	Turbidity	NTU	0		5	
8/10/2024	E. coli	mpn/100 mL	< 1	0		
8/10/2024	Free Chlorine	mg/L	1.25	0.2 - 5		
8/10/2024	pH		8.12		6.5 - 8.5	
8/10/2024	Temperature	C	22.9		30	
8/10/2024	Total Chlorine	mg/L	1.23	5		
8/10/2024	Total Coliforms	mpn/100 mL	< 1	0		
8/10/2024	Turbidity	NTU	0.07		5	
30/09/2024	E. coli	mpn/100 mL	< 1	0		
30/09/2024	Free Chlorine	mg/L	1.55	0.2 - 5		
30/09/2024	pH		8.09		6.5 - 8.5	
30/09/2024	Temperature	C	23		30	
30/09/2024	Total Chlorine	mg/L	1.63	5		
30/09/2024	Total Coliforms	mpn/100 mL	< 1	0		
30/09/2024	Turbidity	NTU	0.07		5	
23/09/2024	E. coli	mpn/100 mL	< 1	0		
23/09/2024	Free Chlorine	mg/L	1.51	0.2 - 5		
23/09/2024	pH		8.13		6.5 - 8.5	
23/09/2024	Temperature	C	20.3		30	
23/09/2024	Total Chlorine	mg/L	1.53	5		
23/09/2024	Total Coliforms	mpn/100 mL	< 1	0		
23/09/2024	Turbidity	NTU	0.19		5	
16/09/2024	E. coli	mpn/100 mL	< 1	0		
16/09/2024	Free Chlorine	mg/L	1.72	0.2 - 5		
16/09/2024	pH		8.06		6.5 - 8.5	
16/09/2024	Temperature	C	19.6		30	
16/09/2024	Total Chlorine	mg/L	1.65	5		
16/09/2024	Total Coliforms	mpn/100 mL	< 1	0		
16/09/2024	Turbidity	NTU	0.13		5	
9/09/2024	E. coli	mpn/100 mL	< 1	0		
9/09/2024	Free Chlorine	mg/L	1.46	0.2 - 5		
9/09/2024	pH		8.12		6.5 - 8.5	
9/09/2024	Temperature	C	19.3		30	
9/09/2024	Total Chlorine	mg/L	1.53	5		
9/09/2024	Total Coliforms	mpn/100 mL	< 1	0		
9/09/2024	Turbidity	NTU	0		5	
2/09/2024	E. coli	mpn/100 mL	< 1	0		
2/09/2024	Free Chlorine	mg/L	1.5	0.2 - 5		
2/09/2024	pH		8.1		6.5 - 8.5	
2/09/2024	Temperature	C	19.4		30	
2/09/2024	Total Chlorine	mg/L	1.52	5		
2/09/2024	Total Coliforms	mpn/100 mL	< 1	0		
2/09/2024	Turbidity	NTU	0.19		5	