

**Kenebri Water Supply - Microbiological Test Results
(from the NSW Drinking Water Database)**

Sample Collection Date	Tested Parameter	Units	Test Result	ADWG Guideline Values Health	ADWG Guideline Values Aesthetic	Laboratory Comments
9/10/2024	pH		7.9300		6.5 - 8.5	,Field result entered as provided
9/10/2024	Free Chlorine	mg/L	1.2100	0.2 - 5		,Field result entered as provided
9/10/2024	E. coli	mpn/100 mL	< 1	0		,Field result entered as provided
9/10/2024	Temperature	C	20.9000		30	,Field result entered as provided
9/10/2024	Turbidity	NTU	0.2000		5	,Field result entered as provided
9/10/2024	Total Coliforms	mpn/100 mL	< 1	0		,Field result entered as provided
9/10/2024	Total Chlorine	mg/L	1.1700	5		,Field result entered as provided
3/09/2024	pH		7.8800		6.5 - 8.5	
3/09/2024	Free Chlorine	mg/L	1.3700	0.2 - 5		
3/09/2024	E. coli	mpn/100 mL	< 1	0		
3/09/2024	Temperature	C	17.5000		30	
3/09/2024	Turbidity	NTU	1.5900		5	
3/09/2024	Total Coliforms	mpn/100 mL	< 1	0		
3/09/2024	Total Chlorine	mg/L	1.4000	5		
6/08/2024	pH		7.6600		6.5 - 8.5	
6/08/2024	Free Chlorine	mg/L	1.7300	0.2 - 5		
6/08/2024	E. coli	mpn/100 mL	< 1	0		
6/08/2024	Temperature	C	12.9000		30	
6/08/2024	Turbidity	NTU	0.6700		5	
6/08/2024	Total Coliforms	mpn/100 mL	< 1	0		
6/08/2024	Total Chlorine	mg/L	1.7800	5		
2/07/2024	pH		7.3500		6.5 - 8.5	,Late but tested
2/07/2024	Free Chlorine	mg/L	1.7300	0.2 - 5		,Late but tested
2/07/2024	E. coli	mpn/100 mL	< 1	0		,Late but tested
2/07/2024	Temperature	C	13.7000		30	,Late but tested
2/07/2024	Turbidity	NTU	0.5600		5	,Late but tested
2/07/2024	Total Coliforms	mpn/100 mL	< 1	0		,Late but tested
2/07/2024	Total Chlorine	mg/L	1.7400	5		,Late but tested
3/06/2024	pH		7.6200		6.5 - 8.5	
3/06/2024	Free Chlorine	mg/L	1.3800	0.2 - 5		
3/06/2024	E. coli	mpn/100 mL	< 1	0		
3/06/2024	Temperature	C	15.9000		30	
3/06/2024	Turbidity	NTU	0.8500		5	
3/06/2024	Total Coliforms	mpn/100 mL	< 1	0		
3/06/2024	Total Chlorine	mg/L	1.4700	5		
1/05/2024	pH		7.9400		6.5 - 8.5	
1/05/2024	Free Chlorine	mg/L	1.7000	0.2 - 5		
1/05/2024	E. coli	mpn/100 mL	< 1	0		
1/05/2024	Temperature	C	24.0000		30	
1/05/2024	Turbidity	NTU	0.5600		5	
1/05/2024	Total Coliforms	mpn/100 mL	< 1	0		
1/05/2024	Total Chlorine	mg/L	1.8200	5		