

Mendooran Water Supply - Chemistry Test Results
(from the NSW Drinking Water Database)

DateCollected	Characteristic	Units	Test Result	ADWG Health Guideline Value	ADWG Aesthetic Guideline Value
11/03/2024	Aluminium	mg/L	0.06		0.2
11/03/2024	Antimony	mg/L	< 0.0001	0.003	
11/03/2024	Arsenic	mg/L	0.001	0.01	
11/03/2024	Barium	mg/L	0.1563	2	
11/03/2024	Boron	mg/L	0.0311	4	
11/03/2024	Cadmium	mg/L	< 0.0001	0.002	
11/03/2024	Calcium	mg/L	57.1		10000
11/03/2024	Chloride	mg/L	281		250
11/03/2024	Chromium	mg/L	< 0.001	0.05	
11/03/2024	Copper	mg/L	0.024	2	1
11/03/2024	Fluoride	mg/L	0.29	1.5	
11/03/2024	Iodine	mg/L	0.06		0.15
11/03/2024	Iron	mg/L	0.4		0.3
11/03/2024	Lead	mg/L	0.0007	0.01	
11/03/2024	Magnesium	mg/L	49.62		10000
11/03/2024	Manganese	mg/L	0.1022	0.5	0.1
11/03/2024	Mercury	mg/L	< 0.0008	0.001	
11/03/2024	Molybdenum	mg/L	0.0009	0.05	
11/03/2024	Nickel	mg/L	0.0008	0.02	
11/03/2024	Nitrate	mg/L	< 1	50	
11/03/2024	Nitrite	mg/L	< 0.1	3	
11/03/2024	pH		8.2		6.5
11/03/2024	Selenium	mg/L	< 0.007	0.01	
11/03/2024	Silver	mg/L	< 0.0002	0.1	
11/03/2024	Sodium	mg/L	148		180
11/03/2024	Sulfate	mg/L	5		250
11/03/2024	Total Dissolved Solids (TDS)	mg/L	608		10000
11/03/2024	Total Hardness as CaCO3	mg/L	346.9		200
11/03/2024	True Colour	Hazen Units (HU)	1		15
11/03/2024	Turbidity	NTU	1.3		5
11/03/2024	Uranium	mg/L	< 0.0001	0.02	
11/03/2024	Zinc	mg/L	0.02		3