

Mendooran Water Supply - Microbiological Test Results (From the NSW Drinking Water Database)

Sample Collection						
Date	Tested Parameter	Units	Test Results	ADWG Guideline Values Health	ADWG Guideline Values Aesthetic	Laboratory Comments
17/02/2025	E. coli	mpn/100 mL	< 1	0		
17/02/2025	Free Chlorine	mg/L	0.41	0.2 - 5		
17/02/2025	pH		8.22		6.5 - 8.5	
17/02/2025	Temperature	C	26.9		30	
17/02/2025	Total Chlorine	mg/L	0.79	5		
17/02/2025	Total Coliforms	mpn/100 mL	< 1	0		
17/02/2025	Turbidity	NTU	1.9		5	
3/02/2025	E. coli	mpn/100 mL	< 1	0		
3/02/2025	Free Chlorine	mg/L	1.04	0.2 - 5		
3/02/2025	pH		8.2		6.5 - 8.5	
3/02/2025	Temperature	C	29		30	
3/02/2025	Total Chlorine	mg/L	1.11	5		
3/02/2025	Total Coliforms	mpn/100 mL	< 1	0		
3/02/2025	Turbidity	NTU	0.09		5	
20/01/2025	E. coli	mpn/100 mL	< 1	0		
20/01/2025	Free Chlorine	mg/L	0.03	0.2 - 5		
20/01/2025	pH		8.21		6.5 - 8.5	
20/01/2025	Temperature	C	26.4		30	
20/01/2025	Total Chlorine	mg/L	0.09	5		
20/01/2025	Total Coliforms	mpn/100 mL	< 1	0		
20/01/2025	Turbidity	NTU	0.38		5	
6/01/2025	E. coli	mpn/100 mL	< 1	0		
6/01/2025	Free Chlorine	mg/L	0.88	0.2 - 5		
6/01/2025	pH		8.2		6.5 - 8.5	
6/01/2025	Temperature	C	26.4		30	
6/01/2025	Total Chlorine	mg/L	1.19	5		
6/01/2025	Total Coliforms	mpn/100 mL	< 1	0		
6/01/2025	Turbidity	NTU	0.13		5	
16/12/2024	E. coli	mpn/100 mL	< 1	0		
16/12/2024	Free Chlorine	mg/L	0.51	0.2 - 5		
16/12/2024	pH		8.21		6.5 - 8.5	
16/12/2024	Temperature	C	26.3		30	
16/12/2024	Total Chlorine	mg/L	1.01	5		
16/12/2024	Total Coliforms	mpn/100 mL	< 1	0		
16/12/2024	Turbidity	NTU	0.13		5	
2/12/2024	E. coli	mpn/100 mL	< 1	0		
2/12/2024	Free Chlorine	mg/L	0.1	0.2 - 5		
2/12/2024	pH		8.2		6.5 - 8.5	
2/12/2024	Temperature	C	24.9		30	
2/12/2024	Total Chlorine	mg/L	0.21	5		
2/12/2024	Total Coliforms	mpn/100 mL	< 1	0		
2/12/2024	Turbidity	NTU	0.44		5	
18/11/2024	E. coli	mpn/100 mL	< 1	0		
18/11/2024	Free Chlorine	mg/L	1.05	0.2 - 5		
18/11/2024	pH		8.18		6.5 - 8.5	
18/11/2024	Temperature	C	24.3		30	
18/11/2024	Total Chlorine	mg/L	1.09	5		
18/11/2024	Total Coliforms	mpn/100 mL	< 1	0		
18/11/2024	Turbidity	NTU	0.01		5	
4/11/2024	E. coli	mpn/100 mL	< 1	0		
4/11/2024	Free Chlorine	mg/L	1.13	0.2 - 5		
4/11/2024	pH		8.58		6.5 - 8.5	
4/11/2024	Temperature	C	27.1		30	

4/11/2024	Total Chlorine	mg/L	1.17	5		
4/11/2024	Total Coliforms	mpn/100 mL	< 1	0		
4/11/2024	Turbidity	NTU	0.01		5	
21/10/2024	E. coli	mpn/100 mL	< 1	0		
21/10/2024	Free Chlorine	mg/L	2.23	0.2 - 5		
21/10/2024	pH		8.22		6.5 - 8.5	
21/10/2024	Temperature	C	18.9		30	
21/10/2024	Total Chlorine	mg/L	2.34	5		
21/10/2024	Total Coliforms	mpn/100 mL	< 1	0		
21/10/2024	Turbidity	NTU	0		5	
8/10/2024	E. coli	mpn/100 mL	< 1	0		
8/10/2024	Free Chlorine	mg/L	0.32	0.2 - 5		
8/10/2024	pH		8.16		6.5 - 8.5	
8/10/2024	Temperature	C	22.1		30	
8/10/2024	Total Chlorine	mg/L	0.64	5		
8/10/2024	Total Coliforms	mpn/100 mL	< 1	0		
8/10/2024	Turbidity	NTU	0.19		5	
23/09/2024	E. coli	mpn/100 mL	< 1	0		
23/09/2024	Free Chlorine	mg/L	0.05	0.2 - 5		
23/09/2024	pH		8.25		6.5 - 8.5	
23/09/2024	Temperature	C	19.2		30	
23/09/2024	Total Chlorine	mg/L	0.14	5		
23/09/2024	Total Coliforms	mpn/100 mL	< 1	0		
23/09/2024	Turbidity	NTU	0.44		5	
9/09/2024	E. coli	mpn/100 mL	< 1	0		
9/09/2024	Free Chlorine	mg/L	2.67	0.2 - 5		
9/09/2024	pH		8.2		6.5 - 8.5	
9/09/2024	Temperature	C	16		30	
9/09/2024	Total Chlorine	mg/L	2.69	5		
9/09/2024	Total Coliforms	mpn/100 mL	< 1	0		
9/09/2024	Turbidity	NTU	0		5	