

**Mendooran Water Supply - Microbiological Test Results**  
(from the NSW Drinking Water Database)

Sample Collection Date	Tested Parameter	Units	Test Result	ADWG Guideline Values Health	ADWG Guideline Values Aesthetic	Labratory Comments
8/10/2024	pH		8.1600		6.5 - 8.5	
8/10/2024	Free Chlorine	mg/L	0.3200	0.2 - 5		
8/10/2024	E. coli	mpn/100 mL	< 1	0		
8/10/2024	Temperature	C	22.1000		30	
8/10/2024	Turbidity	NTU	0.1900		5	
8/10/2024	Total Coliforms	mpn/100 mL	< 1	0		
8/10/2024	Total Chlorine	mg/L	0.6400	5		
23/09/2024	pH		8.2500		6.5 - 8.5	
23/09/2024	Free Chlorine	mg/L	0.0500	0.2 - 5		
23/09/2024	E. coli	mpn/100 mL	< 1	0		
23/09/2024	Temperature	C	19.2000		30	
23/09/2024	Turbidity	NTU	0.4400		5	
23/09/2024	Total Coliforms	mpn/100 mL	< 1	0		
23/09/2024	Total Chlorine	mg/L	0.1400	5		
9/09/2024	pH		8.2000		6.5 - 8.5	
9/09/2024	Free Chlorine	mg/L	2.6700	0.2 - 5		
9/09/2024	E. coli	mpn/100 mL	< 1	0		
9/09/2024	Temperature	C	16.0000		30	
9/09/2024	Turbidity	NTU	0.0000		5	
9/09/2024	Total Coliforms	mpn/100 mL	< 1	0		
9/09/2024	Total Chlorine	mg/L	2.6900	5		
26/08/2024	pH		8.2100		6.5 - 8.5	
26/08/2024	Free Chlorine	mg/L	3.3900	0.2 - 5		
26/08/2024	E. coli	mpn/100 mL	< 1	0		
26/08/2024	Temperature	C	15.6000		30	
26/08/2024	Turbidity	NTU	2.2800		5	
26/08/2024	Total Coliforms	mpn/100 mL	< 1	0		
26/08/2024	Total Chlorine	mg/L	3.4500	5		
12/08/2024	pH		8.2000		6.5 - 8.5	,Late but tested. Field result entered as provided
12/08/2024	Free Chlorine	mg/L	4.6000	0.2 - 5		,Late but tested. Field result entered as provided
12/08/2024	E. coli	mpn/100 mL	< 1	0		,Late but tested. Field result entered as provided
12/08/2024	Temperature	C	13.0000		30	,Late but tested. Field result entered as provided
12/08/2024	Turbidity	NTU	1.3200		5	,Late but tested. Field result entered as provided
12/08/2024	Total Coliforms	mpn/100 mL	< 1	0		,Late but tested. Field result entered as provided
12/08/2024	Total Chlorine	mg/L	7.2700	5		,Late but tested. Field result entered as provided
29/07/2024	pH		8.2200		6.5 - 8.5	
29/07/2024	Free Chlorine	mg/L	2.3300	0.2 - 5		
29/07/2024	E. coli	mpn/100 mL	< 1	0		
29/07/2024	Temperature	C	14.8000		30	
29/07/2024	Turbidity	NTU	0.0600		5	
29/07/2024	Total Coliforms	mpn/100 mL	< 1	0		
29/07/2024	Total Chlorine	mg/L	2.3700	5		
15/07/2024	Total Chlorine	mg/L	2.6000	5		,Field result entered as provided
15/07/2024	Total Coliforms	mpn/100 mL	< 1	0		,Field result entered as provided
15/07/2024	Turbidity	NTU	0.0000		5	,Field result entered as provided
15/07/2024	Temperature	C	12.4000		30	,Field result entered as provided
15/07/2024	E. coli	mpn/100 mL	< 1	0		,Field result entered as provided
15/07/2024	Free Chlorine	mg/L	2.6900	0.2 - 5		,Field result entered as provided
15/07/2024	pH		8.1800		6.5 - 8.5	,Field result entered as provided
1/07/2024	pH		8.1600		6.5 - 8.5	
1/07/2024	Free Chlorine	mg/L	2.2700	0.2 - 5		
1/07/2024	E. coli	mpn/100 mL	< 1	0		
1/07/2024	Temperature	C	12.7000		30	
1/07/2024	Turbidity	NTU	0.2300		5	
1/07/2024	Total Coliforms	mpn/100 mL	< 1	0		
1/07/2024	Total Chlorine	mg/L	2.5000	5		
17/06/2024	pH		8.1800		6.5 - 8.5	
17/06/2024	Free Chlorine	mg/L	2.7400	0.2 - 5		
17/06/2024	E. coli	mpn/100 mL	< 1	0		
17/06/2024	Temperature	C	15.4000		30	
17/06/2024	Turbidity	NTU	0.1000		5	
17/06/2024	Total Coliforms	mpn/100 mL	< 1	0		
17/06/2024	Total Chlorine	mg/L	2.9100	5		
5/06/2024	pH		8.2000		6.5 - 8.5	
5/06/2024	Free Chlorine	mg/L	3.4900	0.2 - 5		
5/06/2024	E. coli	mpn/100 mL	< 1	0		
5/06/2024	Temperature	C	15.1000		30	
5/06/2024	Turbidity	NTU	1.0000		5	
5/06/2024	Total Coliforms	mpn/100 mL	< 1	0		
5/06/2024	Total Chlorine	mg/L	3.7000	5		
20/05/2024	pH		8.2100		6.5 - 8.5	
20/05/2024	Free Chlorine	mg/L	2.2300	0.2 - 5		
20/05/2024	E. coli	mpn/100 mL	< 1	0		
20/05/2024	Temperature	C	15.3000		30	
20/05/2024	Turbidity	NTU	0.8100		5	
20/05/2024	Total Coliforms	mpn/100 mL	< 1	0		
20/05/2024	Total Chlorine	mg/L	2.2300	5		
8/05/2024	pH		7.5500		6.5 - 8.5	
8/05/2024	Free Chlorine	mg/L	2.9800	0.2 - 5		
8/05/2024	E. coli	mpn/100 mL	< 1	0		

8/05/2024	Temperature	C	19.7000		30	
8/05/2024	Turbidity	NTU	0.2500		5	
8/05/2024	Total Coliforms	mpn/100 mL	< 1	0		
8/05/2024	Total Chlorine	mg/L	3.2800	5		
22/04/2024	pH		8.2000		6.5 - 8.5	,Field result entered as provided
22/04/2024	Free Chlorine	mg/L	4.0900	0.2 - 5		,Field result entered as provided
22/04/2024	E. coli	mpn/100 mL	< 1	0		,Field result entered as provided
22/04/2024	Temperature	C	19.3000		30	,Field result entered as provided
22/04/2024	Turbidity	NTU	0.5100		5	,Field result entered as provided
22/04/2024	Total Coliforms	mpn/100 mL	< 1	0		,Field result entered as provided
22/04/2024	Total Chlorine	mg/L	4.2800	5		,Field result entered as provided